

Effluent analysis*

Parameter	Unit	jan-22	feb-22	mar-22	apr-22	may-22	Limit DS°90***
Oils and fats	mg/l	7.00	7.00	4.00	10.00	10.00	150.00
Aluminum	mg/l	0.19	< 0.10	< 0.10	< 0.10	< 0.10	10.00
SAAM detergent**	mg/l	< 0.50	< 0.50	< 0.50	< 0.50	< 0.50	15.00
Settleable solids	ml/l/h	< 0.50	< 0.50	< 0.50	< 0.50	< 0.50	20.00
Total suspended solids	mg/l	31.00	16.00	23.00	18.00	44.00	300.00

* Analysis results according to DFZ/RPM 893 of the Superintendence of the Environment of the Government of Chile.

** Substances active to methylene blue

*** Maximum limit allowed according to Supreme Decree No. 90, Table No. 5