

Effluent analysis*

Parameter	Unit	apr-25	may-25	jun-25	jul-25	aug-25	Limit DS°90***
Oils and fats	mg/l	7.00	14.00	14.00	< 14.00	< 14.00	150.00
Aluminum	mg/l	< 0.2041	< 0.10	< 0.10	0.0017	0.0017	10.00
SAAM detergent**	mg/l	< 0.50	< 0.50	< 0.50	0.72	0.57	15.00
Settleable solids	ml/l/h	< 0.50	< 0.50	< 0.50	< 0.20	< 0.20	20.00
Total suspended solids	mg/l	61.00	38.00	184.00	33.00	54.00	300.00

* Analysis results according to DFZ/RPM 893 of the Superintendence of the Environment of the Government of Chile.

** Substances active to methylene blue

*** Maximum limit allowed according to Supreme Decree No. 90, Table No. 5