

Effluent analysis*

Parameter	Unit	aug-25	sep-25	oct-25	nov-25	dec-25	Limit DS°90***
Oils and fats	mg/l	< 14.00	< 14.00	< 14.00	< 14.00	< 14.00	150.00
Aluminum	mg/l	0.017	0.017	0.017	0.017	0.017	10.00
SAAM detergent**	mg/l	0.57	0.17	0.30	0.17	0.17	15.00
Settleable solids	ml/l/h	< 0.20	< 0.20	< 0.20	< 0.20	< 0.20	20.00
Total suspended solids	mg/l	54.00	45.00	74.00	19.00	46.00	300.00

* Analysis results according to DFZ/RPM 893 of the Superintendence of the Environment of the Government of Chile.

** Substances active to methylene blue

*** Maximum limit allowed according to Supreme Decree No. 90, Table No. 5