

Effluent analysis*



Parameter	Unit	apr-26	may-26	jun-26	jul-26	aug-26	Limit DS°90***
Oils and fats	mg/l	< 14.00	< 14.00	< 14.00	< 14.00	< 14.00	150.00
Aluminum	mg/l	0.017	0.017	0.017	0.017	0.017	10.00
SAAM detergent**	mg/l	0.17	0.17	0.17	0.66	0.74	15.00
Settleable solids	ml/l/h	< 0.20	< 0.20	< 0.20	< 0.20	< 0.20	20.00
Total suspended solids	mg/l	16.00	8.00	20.00	82.00	71.00	300.00

* Analysis results according to DFZ/RPM 893 of the Superintendence of the Environment of the Government of Chile.

** Substances active to methylene blue

*** Maximum limit allowed according to Supreme Decree No. 90, Table No. 5